



State of New Hampshire

DEPARTMENT OF SAFETY

Division of Fire Safety

Office of the State Fire Marshal

Robert L. Quinn
Commissioner

Office: 110 Smokey Bear Boulevard, Concord, NH 03301

Mailing Address: 33 Hazen Drive, Concord, NH 03305

Telephone: 603-223-4289 • Fax: 603-223-4294

www.nh.gov/firesafety



Paul J. Parisi
State Fire Marshal

200074

Main Building - DHHS
105 Pleasant St. Concord

INSPECTION REQUESTS
603-223-4289 #1
dos.fmo.inspec@dos.nh.gov

****Inspection requests MUST contain: Address, permit number, inspection type, contact name and phone number.****
Requests shall be made with at least 48-hours notice prior to requested date of inspection. **THIS CARD SHALL REMAIN ONSITE AT ALL TIMES AND PRESENTED TO INSPECTOR AT EACH INSPECTION.**

PERMIT BECOMES NULL AND VOID unless the work on the site authorized by such permit is commenced within 180 days after its issuance, or if the work authorized on the site by such permit is suspended or abandoned for a period of 180 days after the work is commenced. IBC 105.5.

DESCRIPTION OF WORK: Construct new 1,611SF three-story elevator at north side of main building with connection from Peaslee Wing to North Pavillion.

INSPECTION	DATE	INIT	INSPECTION	DATE	INIT	INSPECTION	DATE	INIT
Temp Electrical			Rough Fire Sprinkler Pipe			Elec Trench		
Footings			Rough Fire Alarm			U/G Gas line		
Foundation			Rough Elec			U/G Gas test		
U/G Electrical			Rough Fuel			Bldg Gas		
U/G Plumbing			Rough Mech			Bldg Gas test		
U/G Mech			Rough Plumb			Elec. Meter		
U/G Fire Main			Frame			Kitchen Hood		
Slab on Grade			Fire Stopping			Fire Suppress.		
C.I.P. Walls			DO NOT INSULATE UNTIL ABOVE IS APPROVED			Kit. Suppress.		
CMU								
Floor Joists			Ext Drywall					
U/F Insulation			Insulation					
DO NOT POUR CONCRETE UNTIL ABOVE IS APPROVED			DO NOT DRYWALL UNTIL ABOVE IS APPROVED			FINAL PLUMB		
Floor Nailing			Ext. WRB			FINAL FUEL		
Pre-Wrap			Int. Drywall			FINAL MECH		
Shear Panel			T-Bar Ceiling			FINAL ELEC		
Roof Nail			Fire separation			FINAL F/A		
			Thru-penetrations			FINAL SPRINKLER		
			DO NOT INSTALL FINISHES UNTIL ABOVE IS APPROVED			FINAL BLDG		
						C.O.		

